

Date: August 24, 2023

To: Potential Bidders

Project: Cary High School Security Improvements
(WCPSS # SP20-011)
Dewberry Project 50158827

Owner: Wake County Public School System (WCPSS),
Facilities Design & Construction
111 Corning Road, Suite 190
Cary, NC 27518

Engineer: Dewberry Engineers Inc.
2610 Wycliff Road, Suite 410
Raleigh, NC 27607

RE: Addendum No. 5

This addendum, applicable to the work designated herein, shall be understood to be and is an Addendum to the contract documents and, such, shall become a part of and included in the contract.

Architectural Items:

1. Refer to Specification Section 088813 – Fire Rated Glass, Manufacturers. The products of the following manufacturer are acceptable, provided they comply with the construction documents:

SAFTI FIRST Fire Rated Glazing Solutions.
2. Refer to Specification Section 095110 – Acoustical Lay-In Ceilings. This section is replaced by the enclosed Section 095110 – Acoustical Lay-In Ceilings, dated 8/20/2023. The ceiling system is revised to comply with the existing building's 1 hour rated ceiling – roof assembly rating.

➤ **Note: Bids are due Tuesday, September 12, 2023 @ 11AM.**

Attachments: 1. Revised Specification Section 095110 – Acoustical Lay-In Ceilings

End of Addendum No. 5