

September 29th, 2023

**ADDENDUM NO. 2**

PROJECT: **FORMER WHEELS SKATING CENTER UPFIT – CITY OF DURHAM**

FROM: DTW ARCHITECTS & PLANNERS, LTD.  
3333 Durham Chapel Hill Blvd, Suite D100  
DURHAM, NC 277078  
Phone: 919.317.4020 Fax: 919.317.4023 Email: [info@dtwarch.com](mailto:info@dtwarch.com)

TO: PRIME BIDDERS

This addendum containing the following additions, clarifications, and/or changes, is issued prior to receipt of bids and does hereby become part of the original Contract Documents dated September 1, 2023 and supersedes the original documents in case of conflict. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so will result in the disqualification of the corresponding bid.

This addendum consists of:

01 Sheet – Addendum Index and Questions

**1) QUESTIONS**

- a) Question: Addendum #1 Pre-Bid meeting notes say something different to include in the bid than what the bid forms in the project manual say to include. Which is correct?
  - i) Answer: *The bid requirements and forms IN the project manual are correct and MUST be followed. Please ignore and delete item number #6 of the Pre-Bid meeting notes that details items required for the bid.*
- b) Question: Is a bid bond required for this project?
  - i) Answer: *Yes, a bid bond is required for this project.*
- c) Question: *The roof curb detail is missing from the roof plan. How should the curb be detailed?*
  - i) Answer: *See attached image below. Curb shall be 18-gauge galvalume steel. Units shall be 8" tall minimum.*

