



7327-G West Friendly Ave.  
Greensboro, NC 27410  
P (336) 605-8020  
[Terracon.com](http://Terracon.com)

**Project:** Specifications for McNair Hall, Exterior Façade Repairs Project, North Carolina Agricultural & Technical State University, Greensboro, North Carolina, Project No. SCO # 23-26582-01A

**Agency:** North Carolina Agricultural & Technical State University

**Designer:** Terracon Consultants, Inc.

**Project No.** FY226138

**Date:** November 21, 2023

### **ADDENDUM NO. 3**

The project manual entitled: "Specifications for McNair Hall, Exterior Façade Repairs Project, North Carolina Agricultural & Technical State University, Greensboro, North Carolina, Project No. SCO #23-26582-01A" are amended as follows:

#### **GENERAL INFORMATION**

1. The Bid Open Date has been rescheduled for Thursday December 7, 2023 at 3:00 p.m. Location remains the same.

Q: "Clean all elevations with masonry cleaner once all masonry and sealants are completed and cured" – does this mean the entire wall OR just the area that is being worked?

A: North and Northwest Elevations are to be cleaned at areas where brick masonry was removed to replace through wall flashing. The entire South and Southwest Elevations are to be cleaned as they are receiving a new penetrating masonry sealer.

Bidder must acknowledge receipt of the Addendum in the box(es) provided on the Bid Form. Failure to acknowledge may be grounds for rejection of the bid. Nothing herein is to be interpreted or construed as changing any provisions of the specifications except as specifically stated herein.

END OF ADDENDUM