



HIGHFILL

Highfill Infrastructure Engineering, P.C.
2703 Jones Franklin Road, Suite 201
Cary, North Carolina 27518
Tel 919-481-4342 | NC Firm License No. C-2586

To: Prospective Bidders

Copies:

Date: March 1, 2024

Proj. No.: SUR2201

Subject: Addendum No. 2
Surf City WWTF Digester/Sludge Holding Tank
Surf City, NC
Owner: Town of Surf City

ADDENDUM NO. 2

BID DATE: March 7, 2024 @ 2:00 PM

Please be advised of the following changes in the plans and specifications for this project:

- Item 1.1:** No air flow meters are required for this project.
- Item 1.2:** The existing SBR control panel shall be used to accommodate the upgrades. Existing PLC and operator interface to incorporate the new digester will require reprogramming. Specification Section 33 31 11 – Wastewater Pumping Stations apply only to panels required for the two interconnect pumps and digester decanter pumps.
- Item 1.3:** Blower enclosure shall be fabricated out of aluminum to match existing aerobic digester blowers.
- Item 1.4:** Surf City will provide pile PDA testing and observation.

No further changes at this time.

Please acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may constitute grounds for the rejection of your Bid.

HIGHFILL INFRASTRUCTURE ENGINEERING, P.C.

Jeffrey Ray, P.E.